

**ADDENDUM# 1**  
**MAINTENANCE SHOP ENCLOSURE AT PARKING GARAGE**

**Bid # 6170F**

**October 22, 2010**

**Dear Vendors:**

**The Contract Bidding Documents pursuant to Bid # 6170F are hereby revised as follows:**

**The following are in response to RFI's received:**

- 1. Will parking fees be waived?**
  - a. Yes, contractors and subcontractors will be given parking access.**
- 2. Will permit fees be waived?**
  - a. The general building permit is in place. The contractor will need to apply for electrical and mechanical permits. Contractor will work with the construction manager to ensure proper permitting and inspections. Town permit fees are waived with contract.**
- 3. Is painting for new walls only? Is it for both sides?**
  - a. No, just paint doors and frames.**
- 4. Can the top and bottom anchors be drilled and epoxy rebar? if so, details on length, size, locations, etc,**
  - a. Top anchors should not penetrate more than 1" into beam.**
- 5. (Drawings/plans) Shows block cells filled. Are both walls filled top to bottom, or certain areas up to a certain height, please explain what you would like.**
  - a. Vertical rebar should be #4 at 32" o.c. and those cells should be grouted solid. Bar should be attached to top and bottom pins. Bottom pin can be rebar drilled and epoxyied into floor slab. Provide an 8" bond beam at door head height with 2 #4 rebars along entire length of new wall.**
- 6. Can we use the light weight block?**
  - a. No.**
- 7. Are the electrical plugs on the inside of the wall or outside?**
  - a. Both sides, as indicted on drawings.**

Thank you for your patience, time and consideration.

Sincerely,



Tammy Bradley, CPM, C.P.P.B.  
Sr. Buyer

C: Joe Mercieri, Capital Projects Manager  
Mark Welch, Principal Oak Park Architects



TOWN OF WEST HARTFORD 50 SOUTH MAIN STREET  
TOWN OF WEST HARTFORD, CT 06107-2431  
(860) 561-7470 FAX: 561-7492



Printed on Recycled Paper